



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

August 7, 2008

STRATFORD HOMES LTD.
STEVE SCHOENFUSS
PO BOX 37
STRATFORD WI 54484

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: STRATFORD HOMES LTD.
Product Name: PEX WATER LINES
Model Number(s): TYPICAL BATHROOM WITH OR WITHOUT WHIRLPOOL TUB AND/OR SECOND LAVATORY,
HALF BATH, BATHTUB OR SHOWER, KITCHEN SINK WITH OR WITHOUT DISHWASHER,
CLOTHES WASHER, LAUNDRY TRAY, AND OUTSIDE SILL FAUCET
Product File No: 20080443

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The flowing water supply pressure at the point(s) of connection must be at least equal to 25 psig for water closets and 8 psig for outlets of all other fixtures supplies or the pressure required by the fixture manufacturer, whichever is greater.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

This approval supersedes the approval issued on October 14, 2003 under product file number 20030425.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030425.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov